



APPROVALS®

Certificate of Approval

Certificate No.: SAA111996

Date of Issue: 22 December 2011

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

Certificate Holder: Sungrow Power Supply Co., Ltd.
No. 2, Tianhu Road,
New and High Technology Development Zone,
Hefei, Anhui 230088
P.R. China

Class Description: Non-Declared
Product Description: Grid-connected Solar Inverter
Brand Name: Sungrow
Model No.: SG15KTL
Markings: Input: 250-1000Vdc, MPPT: 380-800Vdc,
Max 1000Vdc, Max 2x20A IP65
Output: 3Ø 400Vac 50Hz, Max 24A, 15000W
Standard: AS 4777.2:2005
AS 4777.3:2005
AS/NZS 3100:2009 Inc A1
Conditions: Nil

Approval Mark: SAA111996

Date First Registered: 22 December 2011

Date of Expiry: 22 December 2016


For and on Behalf of
SAA Approvals Pty Ltd



JAS-ANZ





APPROVALS®

Certificate of Approval

Addendum

Certificate No.: SAA111996

Date of Issue: 23 December 2011

Class Description: Non-Declared
Product Description: Grid-connected Solar Inverter

Additional Models

SG12KTL

SG10KTL

Description

Similar to SG15KTL except rated input MPPT 330-800Vdc and rated output 12000W 19A.

Similar to SG15KTL except rated input MPPT 250-800Vdc and rated output 10000W 16A.



For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd Electrical Product Safety Certification Scheme as accredited by JAS-ANZ under ISO/IEC Guide 65 certifies that the electrical product described on this certificate complies with the minimum electrical safety requirements for which the application has been made.

JAS-ANZ

